

GUIDELINE FOR BUSINESS SAFETY INSPECTION (CCO)

(THIS IS ONLY A SAMPLE OF ITEMS THE INSPECTOR MAY CHECK FOR)

(PLEASE GO THROUGH THE LIST)

A REPRESENTATIVE MUST BE ON LOCATION

ADDRESS #'S (Arabic lettering, 3 inches mounted to front wall or porch and 30 inches above ground) PASS FAIL

SMOKE ALARMS Ten Year Sealed battery-powered single station smoke alarms shall be installed where no smoke alarms exist or when replacing similar battery-powered single station smoke alarms. **A/C powered single or multi station smoke alarms not be replaced with battery-powered smoke alarms.** (minimum one each floor or front & back)

PASS FAIL

CARBON MONOXIDE DETECTOR (minimum one each floor or front & back) PASS FAIL

FIRE EXTINGUISHER (MOUNTED WAIST LEVEL IS ACCEPTED) **MUST BE A 2A/10BC FIRE EXTINGUISHER, not to exceed 10lbs.**


PASS FAIL

SIDE WALKS & DRIVEWAYS (No cracks and no unevenness) PASS FAIL
(No skim coating or ramping aloud)
(MUST BE VISABLE - REMOVE SNOW AND ICE - NO PARKING)

LOADING DOCK, RAMP OR DECK (front & rear) (Must be well maintained and sturdy) PASS FAIL

WINDOWS OPERABLE & IN DECENT CONDITION PASS FAIL

RAILING ON STAIRS (4 steps or more must have a firmly secured railing) PASS FAIL



WATER CHECK (flush, drains, hot water) PASS FAIL

EXIT LIGHTS, EMERGENCY LIGHTS, LIGHT SWITCHES & RECEPTACLES
(must have covers on them) PASS FAIL

GENERAL CONDITION (no holes in walls, floors and ceiling and painted) PASS FAIL

SUMP PUMP MUST NOT BE TIED INTO SEWER SYSTEM N/A PASS FAIL

CONDITION OF YARD & PROPERTY (grass cut and yard trimmed etc.) PASS FAIL

SECONDARY POWER SOURCE (solar power or generators) AS OF 2/3/25 LABELS MUST
BE ON ELECTRIC PANELS AND ELECTRIC MEETERS advising secondary power source
N/A PASS FAIL

SOLAR PANELS AND ELECTRIC VEHICLE CHARGES MUST HAVE BEEN PERMITTED
N/A PASS FAIL

VIOLATIONS (other than above) PASS FAIL

ANY OPEN PERMITS MUST BE CLOSED/ FINALIZED PASS FAIL